



MODENA CENTRO PROVE s.r.l.
Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78
Tel. 059 822417 r.a. - Fax 059380281 - e-mail : info@modenacentroprove.it -
www.modenacentroprove.com
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 C.F. e P. IVA n. 01592020364



LAB N°1018
Membro degli Accordi di Mutuo
Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual
Recognition Agreements

TEST REPORT: 20185382/2

Modena, 31/07/18

CUSTOMER	FLORIM CERAMICHE SPA - - VIA CANALETTO 24 - 41042 - FIORANO MODENESE - MO
MATERIAL and/o SAMPLE to be tested	porcelain tiles;
Denomination	749161 NEUTRA 6.0 01 BIANCO 6MM 60X120 RET tono t50E cal 5;
Date of sample reception	20/07/2018;
Date of sample acceptance	20/07/2018;
Kind of test executed	Determination of Water Absorption
Referring standards	UNI EN ISO 10545-3:2018
Shifting from standards	No one
Equipment	Scales cod. MCP A241 - Vacuum meter cod. C128 - Forced ventilation stove cod. MCP C43
Subcontracted phases	No one
Sampling made by	Customer

*The test results showing in this Report are only referred to the sample taken by our staff or supplied by the Customer. He commits himself to reproduce integrally this document. Partial reproduction is forbidden.
The times of retain of the samples was indicated in the offer related to the test report.*

Examiner

p.i. Bortolai Alberto

MODENA CENTRO PROVE

Ceramic Dept. Responsible
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

Director
Sant'Unione dr. Giuseppe



DETERMINATION OF WATER ABSORPTION

Beginning date : 26/07/2018

Analysis ending date : 27/07/2018

SAMPLE : Ceramic tiles, marked « **749161 NEUTRA 6.0 01 BIANCO 6MM 60X120 RET tono t50E cal 5** »

RESULTS

Original tile dimensions (cm): 60x120
Tested specimen dimensions (cm): 20x20
N° specimens tested: 12

Sample n°	Water Absorption E_v (%)
1	0,05%
2	0,05%
3	0,05%
4	0,04%
5	0,03%
6	0,03%
7	0,05%
8	0,04%
9	0,04%
10	0,03%
11	0,05%
12	0,03%
Average value	0,04%

Examiner

p.i. Bortolai Alberto

MODENA CENTRO PROVE

Ceramic Dept. Responsible
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

Director
Sant'Unione dr. Giuseppe