

SEDE

Via Martelli, 26 - 40138 Bologna
Tel. 051 534015 - Fax. 051 530085

CERTI.CER.

LABORATORIO DI ZONA

Via Valle d'Aosta, 1 - 41049 Sassuolo
Tel. 0536 802154

Part. IVA 0094778-0375

Bologna, 01/07/14

TEST REPORT N° 3928/14

concerning ceramic tiles
according to EN 14411 (ISO 13006)

Requested by:	FLORIM CERAMICHE S.p.A. - Via Canaletto 24 – 41042 FIORANO MODENESE (MO)
On (date):	14/05/14
For the sample marked:	Ceramic tiles 15 x 90 x 1,0 cm marked "Unglazed ceramic tiles – Brand CASA DOLCE CASA – Serie WOODEN TILE – Articolo WOODEN ALMOND RECLAIMED STRUTTURATO".

**DIN 51130 (06/2004) – Determination of the anti – slip properties –
Workrooms and fields of activities with raised slip danger, walking
method – ramp test**

Surface characteristics

- | | |
|-------------------------------------|------------|
| <input type="checkbox"/> | Smooth |
| <input type="checkbox"/> | Profiled |
| <input type="checkbox"/> | Structured |
| <input checked="" type="checkbox"/> | Rough |

RESULTS

Average total acceptance angle:

26,4°

Movement area (cm³/dm²):

CLASSIFICATION (BGR 181 – 10/2003)

Group of anti – slip properties:

R11

Movement area evaluation group:

Prof. Eng. Giorgio Timellini
Director



The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 pages, this cover included.



Consorzio universitario per la gestione del
«Centro di ricerca e sperimentazione per
l'industria ceramica».
D.P.R. 10-4-1978 n. 806
(G.U. 20-12-1978 n. 353)

Laboratorio autorizzato ad effettuare il
servizio di rilevamento dell'inquinamento
atmosferico.
Decreto MINISTERO SANITÀ 10-8-1974
(G.U. 14-9-1974 n. 240)

Laboratorio iscritto nell'albo dei «Laboratori Esterni
Pubblici e Privati Altamente Qualificati».
Decreto MINISTERO RICERCA SCIENTIFICA 6-6-1983
(G.U. 6-7-1983 n. 183)

Membro ASTM
American Society for
Testing and Materials.