



MODENA CENTRO PROVE s.r.l.
Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78
Tel. 059 822417 r.a. - Fax 059380281 - e-mail : info@modenacentroprove.it -
www.modenacentroprove.com
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 C.F. e P. IVA n. 01592020364



LAB N°1018L

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC Mutual Recognition Agreements

TEST REPORT: 20201959/3

Modena, 26/03/20

CUSTOMER

**FLORIM CERAMICHE SPA - - VIA CANALETTO 24 - 41042 - FIORANO
MODENESE - MO**

MATERIAL and/o SAMPLE to be tested

PORCELAIN TILES;

Denomination

Serie Buildtech 2.0 articolo Mud CE naturale formato 60x120 spessore 10 mm marchio Floor gres;

Date of sample reception

07/02/2020;

Date of sample acceptance

07/02/2020;

Kind of test executed

Determination of Water Absorption

Referring standards

UNI EN ISO 10545-3:2018

Shifting from standards

No one

Equipment

Scales cod. MCP A241 - Vacuum meter cod. C128 - Forced ventilation stove cod. MCP C43

Subcontracted phases

No one

Sampling made by

Customer

*The test results showing in this Report are only referred to the sample taken by our staff or supplied by the Customer. He commits himself to reproduce integrally this document. Partial reproduction is forbidden.
The times of retain of the samples was indicated in the offer related to the test report.*

Examiner

p.i. Bortolai Alberto

MODENA CENTRO PROVE

Ceramic Dept. Responsible
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

Director
Sant'Unione dr. Giuseppe



DETERMINATION OF WATER ABSORPTION

Beginning date : 25/02/2020

Analysis ending date : 26/02/2020

SAMPLE : Ceramic tiles, marked « **Serie Buildtech 2.0 articolo Mud CE naturale formato 60x120 spessore 10 mm marchio Floor gres** »

RESULTS

Original tile dimensions (cm): 60X120
Tested specimen dimensions (cm): 20X20
N° specimens tested: 12

Sample n°	Water Absorption E_v (%)
1	0,09%
2	0,10%
3	0,08%
4	0,10%
5	0,10%
6	0,09%
7	0,10%
8	0,09%
9	0,10%
10	0,10%
11	0,09%
12	0,10%
Average value	0,09%

Examiner

p.i. Bortolai Alberto

MODENA CENTRO PROVE

Ceramic Dept. Responsible
P.I. De Pasquale Roberto

MODENA CENTRO PROVE

Director
Sant'Unione dr. Giuseppe