



TEST REPORT
CERAMIC TILES - DETERMINATION OF ANTI-SLIP CHARACTERISTICS
DIN 51130:2014

Test report n. 4975/2018 /I

Date of report: 29/11/2018

Customer: FLORIM CERAMICHE S.p.a.
Via Canaletto, 24
41042 FIORANO MODENESE (MO)

Requested on: 20/11/2018

Our ref.number: 23819

Execution place of tests: Scandiano (RE)

Description of the sample: "Panel of dimensions 50 x 100 cm covered with ceramic tiles
60x120 cm
marked: Serie Stontech 4.0 formato 60x120 superficie strutturato
marchio Floor gres""

Sampling: carried out by the customer

Receipt date of samples: 22/11/2018

Execution date of tests: start: 29/11/2018 end: 29/11/2018

Test specification: DIN 51130:2014
Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method -
Ramp test

Warnings: *This test report can not be reproduced in part, without our written consent.
The reported results relate only to the samples tested.
The information included in quotation marks was provided by the customer.*





TEST REPORT
CERAMIC TILES - DETERMINATION OF ANTI-SLIP CHARACTERISTICS
DIN 51130:2014

Test report n. 4975/2018 /I

Purpose: The procedure conforms to this standard serves as proof of eligibility for the detection and assessment of anti-slip properties of floor coverings, its use in work rooms and operating areas at high risk of slipping.
The anti-slip properties is the ability of a coating to oppose the slip of the floor.

Surface characteristics: structured

Angle of slip: alpha: 20,7°

Classification:

$\alpha < 6$	$6 \leq \alpha \leq 10$	$10 < \alpha \leq 19$	$19 < \alpha \leq 27$	$27 < \alpha \leq 35$	$\alpha > 35$
NC	R9	R10	R11	R12	R13
-	-	-	X	-	-

NC = not classifiable



THE DIRECTOR
(M.L. Simioli)

End of the document