

**SEDE**

Via Martelli, 26 - 40138 Bologna  
Tel. 051 534015 - Fax. 051 530085

**CERTI.CER.**

**LABORATORIO DI ZONA**

Via Valle d'Aosta, 1 - 41049 Sassuolo  
Tel. 0536 802154

Part. IVA 0094778-0375

Bologna, 14/12/12

**TEST REPORT N° 7256/12**

concerning ceramic tiles  
according to EN 14411 (ISO 13006)

Requested by:	FLORIM CERAMICHE S.p.A. - Via Canaletto 24 - 41042 FIORANO MODENESE (MO)
On (date):	12/12/12
For the sample marked:	Unglazed ceramic tiles of different sizes and thickness 2,0 cm marked "Brand FLOOR GRES - Serie TECH/2".

**DIN 51097 - Slip resistance**

**WORKING CONDITIONS:**

Size of the tested surface (m)	0,50 x 1,20
Joint width (mm):	2
Grout:	Cement mortar
Surface orientation	None

**RESULTS**

Average slip angle:	30°
Application range:	A+B+C

Prof. Eng. Giorgio Timellini  
Director



The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 pages, this cover included.



Consorzio universitario per la gestione del  
«Centro di ricerca e sperimentazione per  
l'industria ceramica».  
D.P.R. 10-4-1978 n. 806  
(G.U. 20-12-1978 n. 353)

Laboratorio autorizzato ad effettuare il  
servizio di rilevamento dell'inquinamento  
atmosferico.  
Decreto MINISTERO SANITÀ 10-8-1974  
(G.U. 14-9-1974 n. 240)

Laboratorio iscritto nell'albo dei «Laboratori Esterni  
Pubblici e Privati Altamente Qualificati».  
Decreto MINISTERO RICERCA SCIENTIFICA 6-6-1983  
(G.U. 6-7-1983 n. 183)

Membro ASTM  
American Society for  
Testing and Materials.