






TEST REPORT: 20193413/3

Modena, 15/05/19

CUSTOMER	FLORIM CERAMICHE SPA - - VIA CANALETTO 24 - 41042 - FIORANO MODENESE - MO
MATERIAL and/o SAMPLE to be tested	porcelain tiles;
Denomination	Serie ETOILE DE REX Articolo TROPICAL MATTE Magnum spessore 6mm formato 120X120 cm marchio Rex;
Date of sample reception	18/04/2019;
Date of sample acceptance	18/04/2019;
Kind of test executed	Determination of Crazing Resistance
Referring standards	UNI EN ISO 10545-11:2000
Shifting from standards	None
Equipment	Autoclave cod. MCP C58
Subcontracted phases	None
Sampling made by	Customer

*The test results showing in this Report are only referred to the sample taken by our staff or supplied by the Customer. He commits himself to reproduce integrally this document. Partial reproduction is forbidden.
The times of retain of the samples was indicated in the offer related to the test report.*

 Examiner p.i. Bortolai Alberto	 MODENA CENTRO PROVE Ceramic Dept. Responsible P.I. De Pasquale Roberto	 MODENA CENTRO PROVE Director Sant'Unione dr. Giuseppe
--	---	--



MODENA CENTRO PROVE s.r.l.
Sede legale e Laboratori: 41123 Modena (Italy) - Via Sallustio, 78
Tel. 059 822417 r.a. - Fax 059380281 -
e-mail : info@modenacentroprove.it - www.modenacentroprove.com
C.C.I.A.A. Modena n. 228587 - Tribunale di Modena n° 2231 - C.F. e P. IVA n. 01592020364

DETERMINATION OF CRAZING RESISTANCE

Beginning date : 08/05/2019

Analysis ending date : 08/05/2019

SAMPLE : Ceramic tiles, marked « **Serie ETOILE DE REX Articolo TROPICAL MATTE Magnum spessore 6mm formato 120X120 cm marchio Rex** »

The test was performed by subjecting whole tiles in an autoclave in order to maintain a pressure of 500 KPa for 2 h.

RESULTS

- Number of test specimens : 5
- Number of test specimens showing crazing : 0
- Description of crazing : No damage

REQUIREMENTS


(Norm UNI EN 14411:2016 Annex G)

No ceramic tiles must present visible defects.

Examiner


p.i. Bortolai Alberto

MODENA CENTRO PROVE


Ceramic Dept. Responsible
P.I. De Pasquale Roberto

MODENA CENTRO PROVE


Director
Sant'Unione dr. Giuseppe